

OPERATIONS MANAGER - STATUS REPORT

October 8th, 2026

Treatment Plants

The treatment plants continue to meet constituent discharge requirements on a routine basis.

Collection System

Crews are continuing with regular operations, daily inspections of District lift stations, issuance of correction notices for repairs on private laterals, and inspections on all repairs. Throughout the month, collection staff inspected waterways and the district effluent outfall line after all rain events. In September the district hydraulically cleaned 14,801 feet of line, and televised 5,934 feet of line.

Regulatory Compliance: District is maintaining a >90% compliance currently through the 2026 calendar year...i.e., < 2 SSO's, RWQCB Plant Discharge Requirements.

Facilities & Infrastructure

There have been no discharge violations due to equipment failure

Talking Points

- District staff have met and discussed the upcoming storm season, annual training for On Call staff in relation to, storm weather events, Outfall breaks, blockages, Lifts Station redirection, as well as plant flow Emergency redirection has been conducted to ensure all staff is as prepared as possible.
- Operations Staff has removed the damaged seals on the existing primary Clarifiers and replaced them with new seals. The Clarifiers have been tested and put back online for the last week with no issues.
- The office of Emergency Services did a site visit with Dawn, Jeanette, and I. They went over our application with us section by section to make suggestions on how to fill in the portions that needed more detail or explanation, as well as additional information they might need before final consideration.