

OPERATIONS MANAGER - STATUS REPORT

March 12th, 2026

Treatment Plants

The treatment plants continue to meet constituent discharge requirements on a routine basis.

Collection System

Crews are continuing with regular operations, daily inspections of District lift stations, issuance of correction notices for repairs on private laterals, and inspections on all repairs. Throughout the month, collection staff inspected waterways and the district effluent outfall line after all rain events. In February the district hydraulically cleaned 12,306 feet of line, and televised 3,201 feet of line.

Regulatory Compliance: District is maintaining a >90% compliance currently through the 2026 calendar year...i.e., < 2 SSO's, RWQCB Plant Discharge Requirements.

Facilities & Infrastructure

There have been no discharge violations due to equipment failure

Talking Points

- Construction continues on the plant upgrades as scheduled. Modification to the inlet pipe for Clarifier #3 has been completed. We are still waiting on a quote for the costs involved with adding a slide gate and walkway to access the slide gate on our T-filter dose tanks. It is Dudeks hope that these modifications will solve the bottlenecking at our plant headworks during storm events while Clarifier #3 is in use.
- Maintenance staff has completed an underdrain and bridge leading through the canal between the road and Well #2 at the ranch. This will ensure easy access to that Well even when water is being distributed to that section of the ranch.
- Bennett Construction has started the second half of the Seeley Creek erosion control/repair project at the plants front gate.
- The drive Unit and bearings have failed on the Cleghorn Secondary Clarifier prompting me to take immediate action requesting quotes for repair parts and labor to get this essential plant process repaired and back online as soon as possible