

## OPERATIONS MANAGER - STATUS REPORT

May 8th, 2025

### Treatment Plants

The treatment plants continue to meet constituent discharge requirements on a routine basis.

### Collection System

Crews are continuing with regular operations, daily inspections of District lift stations, issuance of correction notices for repairs on private laterals, and inspections on all repairs. Throughout the month, collection staff inspected waterways and the district effluent outfall line after all rain events. In April the district hydraulically cleaned 20,287 feet of line, and televised 20,677 feet of line.

Regulatory Compliance: District is maintaining a >90% compliance currently through the 2025 calendar year...i.e., < 2 SSO's, RWQCB Plant Discharge Requirements.

### Facilities & Infrastructure

There have been no discharge violations due to equipment failure

### Talking Points

- Construction continues on the plant upgrades continues as scheduled. Replacement of the failed air compressor heater/evaporation unit was completed on the 7<sup>th</sup>.
- Edison has completed the tree removal on Huston plant road and I have met and walked both Huston and Seeley Creek with the Fire Safe Council and Cal Fire for hazard tree and brush removal from the plant buildings and perimeter.
- The Start up and Testing for the stand by generator was successfully done on Thursday April 10<sup>th</sup> the generator transferred and powered the plant as it was programmed to.
- The Huber Screw presses are functional, but the polymer injection system still needs calibration as it is currently overfeeding the screw presses. I have reached out to all the contractors and Vendors and am working on the proper adjustments.